



NOTES:

- A PVBA SHALL ONLY BE INSTALLED IN VERTICAL CONFIGURATION A MINIMUM OF 12" INCHES ABOVE THE HIGHEST DOWNSTREAM PIPING.
- BACKFLOW ASSEMBLY SHALL BE USC APPROVED FOR WASHINGTON STATE.
- IF INSTALLED INDOORS, PROVIDE FOR OCCASIONAL WATER LEAKAGE FROM AIR INLET PORT.
- INSTALL IN AN ACCESSIBLE LOCATION. DO NOT INSTALL IN AN AREA SUBJECT TO FLOODING OR FREEZING.
- THE WATER LINE SHALL BE TESTED, DISINFECTED AND FLUSHED PRIOR TO INSTALLING THE BACKFLOW ASSEMBLY.
- GATE VALVES, PIPE NIPPLES, AND UNIONS SHALL BE BRASS OR SCHEDULE 80 PVC.
- ALL FASTENERS SHALL BE HOT-DIP GALVANIZED OR STAINLESS STEEL.
- THE BACKFLOW ASSEMBLY SHALL BE TESTED AFTER INSTALLATION AND PRIOR TO ACCEPTANCE AND ALSO ANNUALLY THEREAFTER BY A CERTIFIED BACKFLOW ASSEMBLY TESTER. TEST RESULTS SHALL BE SUBMITTED TO THE CITY OF BAINBRIDGE ISLAND, PUBLIC WORKS DEPARTMENT, OPERATIONS & MAINTENANCE DIVISION.

	CITY OF BAINBRIDGE ISLAND STANDARD DETAILS	
	PRESSURE VACUUM BREAKER ASSEMBLY FOR 2" & SMALLER	
REV.	APPROVED  CITY ENGINEER	DWG. NO. 10-166
	2007-07-08 DATE	